



HLOUBKY ULOŽENÍ					
	SILOVÝ KABEL DO 1kV	SĎĚLOVACÍ KABEL	PLYNOVOD	VODOVOD	KANALIZACE
V CHODNÍKU	0,35 m	0,40 m	0,80 m	1,00 - 1,60 m	min. 1,00m
VE VOLNÉM TERÉNU	0,70 m	0,60 m	0,80 m	1,00 - 1,60 m	min. 1,00m
VE VOZOVCE	1,00 m	0,90 m	1,00 m	1,50 m	min. 1,80m

The diagrams illustrate the cross-section of a drainage system in three different environments:

- CHODNÍK (Sidewalk):** Shows a drainage channel with a cover (35 cm wide) and a 20 cm deep gravel (písek) layer. The channel is 16 cm wide. The surrounding area is soil (zemina) with a 35 cm wide gravel (písek) layer. The total width is 35 cm.
- VOZOVKA (Road):** Shows a drainage channel with a cover (50 cm wide) and a 100 cm deep gravel (písek) layer. The channel is 16 cm wide. The surrounding area is soil (zemina) with a 35 cm wide gravel (písek) layer. The total width is 50 cm.
- VOLNÝ TERÉN (Uneven terrain):** Shows a drainage channel with a cover (35 cm wide) and a 70 cm deep gravel (písek) layer. The channel is 16 cm wide. The surrounding area is soil (zemina) with a 35 cm wide gravel (písek) layer. The total width is 35 cm.

ZODP. PROJEKTANT	VYPRACOVAL	KRESLIL	<div>JOHANA POLÁKOVÁ</div> <div>ELEKTROPROJEKTY</div> <div>SKALKA 27, 470 02 BLÍŽEVEDLY</div> <div>Tel: 733 774 830 IČO: 62784749</div>
JOHANA POLÁKOVÁ	JOHANA POLÁKOVÁ	JOHANA POLÁKOVÁ	
INVESTOR:	MĚSTO ŠLUKNOV		
P.Č. 156, 176/1, 178/4, 180/4, 180/5, 180/6, 180/8, 181, 177/1, 178/1, 179/1, 179/2, 134/1, 134/2 V K.Ú. ŠLUKNOV			
ŠLUKNOV - ZAJIŠTĚNÍ BEZPEČNOSTI V ZÁMEČKÉ ULICI SO 03 VEŘEJNÉ OSVĚTLENÍ			
SITUACE			

FORMÁT	A3
DATUM	II/2023
STUPEŇ	DPS
ČÍSLO ZAK.	8/2023
MĚŘÍTKO	ČÍS. VÝK.
1:500	E1